

THEORY & OBJECTIVE

ENVIRONMENTAL ENGINEERING

*By
Team of
Engineers Academy*

- Covers ESE, GATE, IAS, PSUs, DRDO, ISRO & other Technical Exams.
- Covers complete syllabus & all topics of ESE & GATE examination.
- Thoroughly revised, fully solved & error free book.
- Concise, concept oriented and topicwise presentation & authentic solutions.



ENGINEERS ACADEMY[®]

Your GATEway to Professional Excellence

IES • GATE • PSUs • JTO • IAS • NET

CORPORATE OFFICE

100-102, Ram Nagar, Bambala Puliya, Tonk Road, Pratap Nagar, Jaipur-302033

Ph.: + 91-8094441777

Website : www.engineersacademy.org | **Email:** info@engineersacademy.org

Ajmer | Jaipur | Kota | Jodhpur | Bhilwara | Delhi | Patna | Lucknow | LPU | Ludhiana | Jalandhar | Kanpur | Allahabad

CONTENTS

S.No.	Topic	Page No.
1.	Water Demand & Resources	1 – 12
2.	Quality of Water	13 – 30
3.	Water Purification	31 – 61
4.	Filtration	62 – 81
5.	Disinfection	82 – 92
6.	Miscellaneous Water Treatments	93 – 102
7.	Distribution System	103 – 127
8.	Design of Sewers	128 – 149
9.	Waste Water Characteristics	150 – 168
10.	Treatment of Sewage	169 – 190
11.	Sludge Digestion	191 – 203
12.	Trickling Filters	204 – 216
13.	Activated Sludge Process	217 – 231
14.	Oxidation Ponds	232 – 237
15.	Disposing of The Sewage Effluents	238 – 248
16.	Solid Waste Management	249 – 256
17.	Effect of Air Pollution	257 – 281
18.	Sound Pollution	282 – 288



ENGINEERS ACADEMY
PUBLICATIONS

Log on to : www.eapublications.org | Ph. : 08094441777



WATER DEMAND & RESOURCES

THEORY

1.1 | WATER DEMAND

1.1.1 Domestic Water Demand

The total domestic water consumption usually vary from 50% to 60% of the total water supply to a city. The IS code list down a limit of water consumption between 135 to 225 ltr/capita/day (LPCD). Under ordinary condition (as per IS code) the domestic water demand for a town or a city with full flushing system should be taken as 200 LPCD. Although it can be reduced to 135 LPCD for economical weaker section and LIG colony.

1.1.2 Industrial Water Demand

This quantity varies with number and type of industries present in the city. This consumption under ordinary condition is 50 LPCD. Some industries influence a high water demand like : Paper industry, Textile industries etc.

1.1.3 Institutional and Commercial Water Demand

On an average demand is 20 LPCD. It may be as high as 50 LPCD.

1.1.4 Demand for Public Use

This includes water requirement for parks, gardening washing of roads etc. On this account a normal amount not exceed 5% of consumption may be provided.

1.1.5 Fire Demand

The quantity of water require for fire is not very large. The city upto 50 lakh population hardly amount is 1 LPCD. But this water should be easily available and kept always stored in storage reservoir.

1.1.6 Water Demand for Losses & Theft

This may be as high as 15% of total demand.

1.2 | FACTORS AFFECTING WATER DEMAND

- | | |
|--|---|
| (a) Size of city | (b) Climate condition |
| (c) Industrial and commercial activities | (d) Habits of people |
| (e) Quality of water supply | (f) Pressure in the distribution system. |
| (g) Development of sewage facility. | (h) Cost of water and method of charging. |

1.3 | POPULATION FORECASTING METHODS

Methods are based on laws of probability and growth curve. Following are population forecasting methods :

- | | |
|---|--|
| (a) Arithmetic increase method | (b) Geometric increase method |
| (c) Incremental Increase method | (d) Decreasing rate of growth method |
| (e) Simple graphical method | (f) Comparative graphical method |
| (g) Master plan method or zoning method | (h) The ratio method or apportionment method |
| (i) The logistic curve method | |

Methods are Discussed Below:

(a) Arithmetic Increase Method

This method assumes that the population increases at a constant rate :

$$\frac{dP}{dt} = \text{constnat}$$

Forecasted population (P_n) after 'n' decades

$$P_n = P_0 + n\bar{x}$$

where,

P_0 = Population at last known census.

$\bar{x}$ = Average (Arithmetic mean) of population increase in last decades.

n = No. of decades between last census and future.

(b) Geometric Increase Method

It is also known as 'uniform increase method'.

Forecasted population,

$$P_n = P_0 \left(1 + \frac{r}{100} \right)^n$$

where,

P_0 = Population at last known census.

r = Growth rate (%)

$r = \frac{\text{Increase in population}}{\text{Orginal population}} \times 100$ for each decade.

Knowing as $r_1, r_2, r_3, r_4, \dots, r_n$ for each decade.

The average value of r can be found by

(i) Arithmetic average method

$$r = \frac{r_1 + r_2 + r_3 + \dots + r_n}{n}$$

(ii) Geometric average method

$$r = \left(r_1 \times r_2 \times r_3 \times \dots \times r_n \right)^{\frac{1}{n}}$$

Note: Engineers adopt arithmetic average method since it gives more value than the geometric avg. Method. However GOI manual on water supply recommends 'Geometric mean method'.

(iii) Incremental increase method:

Rate of growth is not assumed constant.

Population

$$P_n = P_0 + n\bar{x} + \frac{n(n+1)}{2}\bar{y}$$

where,

P_0 , n , $\bar{x}$ are as usual.

$\bar{y}$ = Average of Incremental increase of the known decades.

Note: (i) Geometric mean method suitable for younger cities expanding of faster rate.

(ii) Incremental increase method suitable for both old and new cities.

Example: The population of 5 decades from 1930 to 1970 are given below in table. Find out the population after '3' decades beyond the last known decade, by using

(i) Arithmetic mean method

(ii) Geometric mean method

(iii) incremental increase method

Year	1930	1940	1950	1960	1970
Population	25000	28000	34000	42000	47000

Solution:

Col (1)	Col (2)	Col (3)	Col (4)	Col (5)
Year	Population	Increase in population	Growth rate (r) %	Incremental increase
1930	25000			
		3000	$\frac{3000}{25000} \times 100 = 12$	
1940	28000			6000-3000 = 3000
		6000	$\frac{6000}{28000} \times 100 = 21.4$	
1950	34000			8000-6000 = 2000
		8000	$\frac{8000}{34000} \times 100 = 23.5$	
1960	42000			5000-8000 = -3000
		5000	$\frac{5000}{42000} \times 100 = 11.9$	
1970	47000			
Total		$\Sigma = 22000$		$\Sigma = 2000$

(i) Arithmetic mean method:

$$\bar{x} = \frac{\sum \text{col}(3)}{4} = \frac{22000}{4} = 5500$$

$$P_{2000} = P_{1970} + n\bar{x}$$

$$= 47000 + 3 \times 5500 = \mathbf{63500}$$

Ans.

(ii) Geometric mean method :

(a)
$$r = \frac{r_1 + r_2 + r_3 + r_4}{4} = \frac{12 + 21.4 + 23.5 + 11.9}{4} = 17.2\%$$

$$P_{2000} = P_{1970} \left(1 + \frac{r}{100}\right)^n$$

$$\begin{aligned}
 (b) \quad r &= (r_1 r_2 r_3 r_4)^{1/4} \\
 &= (12 \times 21.4 \times 23.5 \times 11.9)^{1/4} \\
 &= 16.37\%
 \end{aligned}$$

So,

$$\begin{aligned}
 P_{2000} &= 47000 \left(1 + \frac{16.37}{100}\right)^3 \\
 &= 74066.62 \approx 74067
 \end{aligned}$$

(iii) Incremental Increase method :

$$\begin{aligned}
 \bar{y} &= \frac{\sum \text{col}(s)}{3} = \frac{2000}{3} = 666.67 \\
 P_{2000} &= P_{1970} + n\bar{x} + \frac{n(n+1)}{2}\bar{y} \\
 &= 47000 + 3 \times 5500 + \frac{3(3+1)}{2} \left(\frac{2000}{3}\right) \\
 &= 67500
 \end{aligned}$$

Ans.

1.4 | WATER RESOURCES

Mainly there are two types of water resources:

1. Surface water resources
2. Ground water resources

1. Surface water resources

- ❖ It consist river, lake, water fall etc.
- ❖ Among all the surface water resources rivers are main.
- ❖ The source of water in river is either rain or melting of ice.

2. Ground water resources

- ❖ The main ground water resources are well and tube-well.
- ❖ The possibility of ground water occurrence depends upon (a) Porosity (b) Permeability

(a) **Porosity** : Indicates voids in which water will be accumulated.

(b) **Permeability** : It represent ability to pass water to itself. Only if permeability is large enough than only water can be taken out from the pores.

1.5 | DARCY'S LAW

As per Darcy the velocity of flow in soil is directly perposonal to hydraulic gradient.

$$\begin{aligned}
 \Rightarrow \quad V &\propto i \\
 \Rightarrow \quad V &= K i \\
 \Rightarrow \quad Q &= KiA
 \end{aligned}$$

Where,

Q = Discharge rate

i = Hydraulic gradient

A = Area of flow

K = Permeability of soil

⇒ In general

$$A = \pi d h$$

But, Area available for flow of the water is only void present in soil mass.

So,

$$A_{\text{actual}} = \eta A$$

where,

η = Porosity

⇒ For the continuity equation,

$$VA = V_{\text{act}} A_{\text{act}}$$

$$V_{\text{act}} = V \left(\frac{A}{A_{\text{act}}} \right)$$

⇒

$$V_{\text{act}} = V_{\text{seepage}} = \frac{V}{\eta}$$

Co-efficient of permeability depends upon pores medium as well as fluid properties.

Co-efficient of permeability is given as

$$K = \frac{Cd^2g}{v}$$

where,

C = shape factor

v = kinematic viscosity of fluid

g = gravity acceleration

d = main or effective size of particle.

The component of permeability which represents only the properties of pores medium is called Intrinsic permeability / Absolute permeability. Given as


$$K_0 = Cd^2$$

$$K_0 = \frac{Kv}{2}$$

$$K_0 = \frac{K\mu}{r}$$

The unit of Intrinsic permeability is “m²” Or “Darcy”

$$1 \text{ darcy} = 9.87 \times 10^{-13} \text{ m}^2$$



1.6 | TYPE OF GROUND LAYERS

On the basis of porosity and permeability the following types of layers are given.

1. **Aquifuse** : Neither pores nor permeable. *Example* : Granite.
2. **Aquitard** : Its permeability is less. It does not yield ground water freely, but seepage is possible through it.
Example : sandy clay.
3. **Aquiclude** : Highly pores but not permeable. *Example* : Clayey soil.
4. **Aquifer** : High pores and enough permeable. *Example*: sand deposits

1.7 | GROUND WATER YIELD

All water in the pores cannot be drained out under gravity. Some water can be retain due to molecular attraction. It is called “Pellicular water”

$$\text{Specific yield} = \frac{\text{Volume of water drain out under gravity}}{\text{Total volume of soil being drain out}}$$

$$\text{Specific retention} = \frac{\text{Volume of water retain}}{\text{Total volume of soil being drain out}}$$


$$\boxed{\text{Specific yield} + \text{Specific retention} = \eta}$$

Smaller the particle size larger will be retention.

1.8 | SPECIFIC CAPACITY

It is a rate of flow from well per unit drawdown. *Various form of under ground source and there exploration:*

1. Infiltration Gallery



infiltration gallery

$$\text{Discharge } Q = \frac{K(H^2 - h_0^2)L}{R}$$



where,

K = Permeability of soil

H = Height of water table

h_0 = height of Infiltration gallery
 L = Length of Infiltration gallery
 R = Distance between water levels


2. Wells



- **Shallow well** : Well lining are resisted by soil friction. It may be deeper than deep well.
- **Deep well** : Well lining rest on the first impervious layer.
- **Cavity Formation** : Due to large discharge from the deep well, upward velocity of flow become more than the critical velocity of flow and hence fine sand is get lifted along the water. More lifting of fine sand cause a cavity below the meta layer.
- It increase the flow area approx 4/3 times.
- Cavity formation is dangerous in shallow well, as well lining may sink. hence discharge from shallow well is limited.

1.9 | YIELD OF OPEN WELL

Yield at open well correctly calculated by pumping test in the field.



$Q_1 = Q_2$ = water level maintain

$Q_1 > Q_2$ = water level increases

$Q_1 < Q_2$ = water level decreases

1.10 | PUMPING TEST

Pumping causes drawdown thus it is adjusted to make water level constant. Under this equilibrium condition rate of pumping will be equal to rate of yield from the cell

$$Q = CAS$$

where,

Q = Discharge

C = Specific capacity per unit area of well

S = Drawdown

A = Area of well (Bottom area)

$$= \frac{\pi}{4} d^2 \text{ (Shallow well)}$$

$$= \frac{4}{3} \times \frac{\pi}{4} d^2 \text{ (for deep well)}$$

If C and A are constant than

$$\frac{Q}{S} = \text{constant.}$$

$$\frac{Q_1}{S_1} = \frac{Q_2}{S_2}$$

The value of 's' for which the velocity become equal to critical velocity (for sand comes out) is called "Critical dispression head". Working head = $\frac{1}{3}$ critical dispression head (generally).

1.11 | RE-CUPERATION TEST



(1)

$t = 0$

(2)

$t = T$

$S = S_1$

$S = S_2$

When pump stopped

$t = T$ after pump stopped

$$\left(\frac{C}{A}\right) = \frac{2.303}{T} \log \left(\frac{S_1}{S_2}\right); \quad Q = \frac{C}{A} \times \text{Volume}$$

where,

$\frac{C}{A}$ = Specific yield or specific capacity

Q = Discharge

Volume = $A_{\text{well}} \times \text{dispression head (H)}$

□□□



OBJECTIVE QUESTIONS

1. Consider the following statements:
The daily per capita consumption of water apparently increase with
1. higher standard of living of people
 2. availability of sewerage in the city
 3. metered water supply
 4. wholesome and potable quality of water
- Which of these statements are correct?
- (a) 1, 2 and 3 (b) 2, 3 and 4
(c) 1, 3 and 4 (d) 1, 2 and 4
2. Water distribution systems are sized to meet the
- (a) maximum hourly demand
 - (b) Average hourly demand
 - (c) maximum daily demand and fire demand
 - (d) average dialy demand and fire demand
3. The present population of a community is 28000 with an average water consumption of $4200 \text{ m}^3/\text{d}$. The existing water treatment plant has a design capacity of $6000 \text{ m}^3/\text{d}$. It is expected that the population will increase to 44000 during the next 20 years. The number of years from now when the plant will reach its design capacity, assuming an arithmetic rate of population growth, will be
- (a) 5.5 years (b) 8.6 years
(c) 15.0 years (d) 16.5 years
4. On which of the following factors, does the population growth in a town normally depend?
1. Birth and death rates
 2. Migrations
 3. Probabilistic growth
 4. Logistic growth
- Select the correct answer using the code given below:
- (a) 1 and 4 (b) 1 and 2
(c) 1, 2 and 3 (d) 2 and 3
5. Which one of the following factors has the maximum effect on figure of per capita demand of water supply of given town?
- (a) Method of charging of the consumption
 - (b) Quality of water
 - (c) System of supply-intermittent
 - (d) Industrial demand
6. In a city with a population of 70,000 water is drawn for domestic purposes from a bell-mouth intake in a canal which runs only for 10 hours a day with a flow depth of 1.5m. If the average consumption per person is 150 lpcd , then the intake load is
- (a) $0.30 \text{ m}^3/\text{s}$ (b) $0.29 \text{ m}^3/\text{s}$
(c) $0.27 \text{ m}^3/\text{s}$ (d) $0.25 \text{ m}^3/\text{s}$
7. Which one of the following methods given the best estimate of population growth of a community with limited land area for future expansion?
- (a) Aritmetical increase method
 - (b) Geometrical increase method
 - (c) Increamental increase method
 - (d) Logistic method
9. Match List-I (Tests) with List-II (Features) and select the correct answer using the codes given below the lists:
- | | |
|---|--|
| List-I
A. Pumping test
B. Recuperation Test
C. Pressure Test
D. Jar Test | List-II
1. The gradual rise of water level in well is observed as time progresses
2. Rate of pumping is adjusted to constant level of water in well |
|---|--|

3. Vigorous mixing of the chemical following by slow mixing.
4. Pipeline is filled up with water, allowed to stand for sometime and then at least double the maximum pressure is applied.
15. The average per capita consumption of water per day in an indian city is about
- (a) 135 l (b) 300 l
(c) 450 l (d) 600 l

Codes: A B C D

- (a) 1 2 3 4
(b) 2 1 4 3
(c) 1 2 4 3
(d) 2 1 3 4
10. The averaging is done for per capita water demand is over a period of time
- (a) 24 hours (b) One years
(c) 10 year (d) 35 years
11. The multiplying factor, as applied to obtain the peak hourly demand, in relation to the maximum daily demand (per hour) is
- (a) 1.5 (b) 1.8
(c) 2.0 (d) 2.7
12. If the average daily water consumption of a city is 24000 cum, the peak hourly demand (or the maximum day) will be
- (a) 1000 cum/hr (b) 1500 cum/hr
(c) 1800 cum/hr (d) 2700 cum/hr
13. Water treatment units may be designed, including 100% reserves, for water demand equal to
- (a) Average daily (b) Twice of average daily
(c) Maximum daily (d) None of the above
14. Distribution system in water supplies, is designed on the basis of
- (a) Average daily demand
(b) Peak hourly demand
(c) coincident draft
(d) Greater of (b) and (c) above
16. Industrial and commercial demand accounts for...of the total demand
- (a) 5% (b) 30%
(c) 20% (d) 10%
17. Water is said to be contaminated, if it contain
- (a) Pathogens
(b) Undesirable suspended matter, making it unfit for drinking and domestic use
(c) Dissolved salts
(d) None of the above
18. 'Wholesome water' does not contain
- (a) Pathogenic bacteria
(b) Suspended matter in quantities harmful to man
(c) Fire and public-use demand
(d) All of the above
19. Industrial and commercial water demand in a city as compared to total demand of city, is
- (a) 10 to 15% (b) 15 to 20%
(c) 20 to 25% (d) 30 to 40%
20. Decrease in per capita consumption occurs by
- (a) Use of metering system
(b) Hot climate
(c) Good quality water is supplied
(d) All of the above

□□□

ANSWERS AND EXPLANATIONS1. *Ans. (d)*

To avoid wastage of water, the government sometimes uses metered water supply. As, in metered water supply, government can keep track amount of water used, it reduces the tendency of people to waste water. All the other statements increases the daily consumption of water.

2. *Ans. (d)*3. *Ans. (c)*

$$P_0 = 28,000$$

Average increase per decade,

$$\bar{x} = \frac{44,000 - 28,000}{2} = 8,000$$

4200 m³/d required for 28,000 persons

6000m³/d sufficient for _____ persons

$$= \frac{28000 \times 6000}{4200} = 40,000$$

$$P_n = P_0 + n\bar{x}$$

$$40,000 = 28,000 + n \cdot 8,000$$

$$n = 1.5 \text{ decades}$$

$$= 15 \text{ years}$$

4. *Ans. (b)*

The population growth of a town depends mainly on three factors:

(i) Births.

(ii) Deaths.

(iii) Migration.

5. *Ans. (d)*

The pressure of industrial activity at a particular place increases the water consumption by large amounts. Many industries require huge amount of water (much more than the domestic demand) and as such, increase the water demand considerably.

6. *Ans. (b)*

$$\text{Population} = 70000$$

$$\text{Avg. consumption} = 150 \text{ lpd.}$$

$$\text{Total daily consumption} = \frac{70000 \times 150}{1000}$$

$$= 10500 \text{ m}^3/\text{day}$$

$$\text{intake load} = \frac{10500}{10 \times 60 \times 50}$$

$$= 0.29 \text{ m}^3/\text{sec.}$$

7. *Ans. (a)*8. *Ans. (b)*9. *Ans. (b)*10. *Ans. (a)*11. *Ans. (d)*12. *Ans. (b)*13. *Ans. (d)*14. *Ans. (a)*15. *Ans. (d)*16. *Ans. (a)*17. *Ans. (b)*18. *Ans. (c)*19. *Ans. (a)*

□□□



QUALITY CONTROL OF WATER

THEORY

Water impurities are classified on the basis of following properties

1. Physical Parameter
2. Chemical Parameter
3. Biological Parameter

2.1 | PHYSICAL PARAMETER

1. Suspended solids
2. Turbidity
3. Taste and odour
4. Colour
5. Temperature

1. Suspended Solids

Source : These are called as physical parameters where as dissolved solids are considered as chemical parameters. SS comes from inorganic particles like silt, clay etc., immiscible liquids like oils and greases and organic particles like plant fiber, algae, etc. Inorganic solids are non-degradable solids.

Note: Problem of SS comes only in surface water but not in groundwater.

Objection : These are objectionable because :

- ✱ Aesthetically displeasing,
- ✱ It provides adsorption sites for chemical and biological agents
- ✱ They may also be biologically active and may form disease causing organisms as well as organisms such as toxin producing strains of algae.

➤ **Measurement :**

Most of the methods are gravimetric i.e. SS are calculated by weighing them. Total solids i.e. all solids (suspended or dissolved) are calculated by evaporating the sample and measuring the residue. Heating temperature is 104°C. Suspended solid is obtained by filtration and heating the residue on filter at 104°C.

$\text{Dissolved solids (DS)} = \text{Total solids (TS)} - \text{Suspended solids (SS)}$

Note : Filtration in real terms does not exactly divides the solids into suspended and dissolved fractions because some colloids may pass through the filter and can get measured along with dissolved fraction.

Hence classification is done as filterable and non-filterable solids.

Hence suspended solids are corresponding to non-filterable solids and dissolved solids are corresponding to filterable solids.

The organic content of both total and dissolved solids can be determined by firing the residue at 650°C.

Organic fraction $\xrightarrow{650^{\circ}\text{C}}$ $\text{CO}_2 + \text{Water} + \text{Other gases}$

Remaining solids are inorganic solids or fixed solids.

➤ **The permissible limits :**

- ❖ For suspended solid as per EPA is 30 mg/l

2. Turbidity:

- **Definition :** Turbidity is the measure of extent to which light is either absorbed or scattered by suspended material in water. It is not a direct quantitative measure of suspended solids.
- **Objection :** Disinfection of turbid water is difficult because the suspended solids may partially shield the organisms from disinfectant.
- ❖ In natural bodies turbidity interferes with light penetration and hence with the photosynthetic reactions (which gives oxygen to the water).
- **Measurement :** Measurement of turbidity is done using the following :
 - (a) Turbidity rod
 - (b) Jackson's turbidimeter
 - (c) Baylis turbidimeter
 - (d) Nephelometer

(a) Turbidity Rod

Rod with platinum needle is inserted inside water and the depth at which platinum needle just becomes invisible gives turbidity in ppm. Turbidity which one milligram of finely divided silica produces in one litre of distilled water is taken as one unit. The permissible limit is 5 - 10 ppm. It is a field method.

Note: Government of India manual gives turbidity in NTU i.e. Nephelometer turbidity unit. Acceptable limit is 1 and cause for rejection is 10.

(b) Jackson's Turbidimeter :

- ❖ The level of water is increased till the image of flame ceases to be seen.
- ❖ The turbidity is measured from graduated glass tube.
- ❖ It is used when turbidity is greater than 25 ppm.
- ❖ It is a laboratory method.

Note: Turbid raw water of natural source has turbidity greater than 25 ppm.

(c) Baylis Turbidimeter and Nephelometer :

Baylis and Nephelometer turbidimeters are based on colour matching techniques. In this case even a small turbidity of one unit or less can be measured. Hence these are most widely used for domestic water supplies. In Baylis turbiditymeter light intensity is measured in the direction of incident light only where as in nephelometer light intensity is measured at right angles to the incident ray. Hence NTU is based on scattering principle. If Formazine, a chemical, is used as base in place of SiO_2 . The turbidity unit is also sometimes called FTU.

3. Taste and Odour

Taste and odour are caused by dissolved gasses like H_2S (Hydrogen sulphide), mercaptans, methane organic matter derived from certain dead or living micro organism, decomposing organic matter, industrial liquid, water containing phenols, cresols, ammonia, agricultural chemicals, high residual chlorine and chloro-phenols.

➤ **Source :**

- ❖ Sulphur imparts rotten egg like taste and odour.
- ❖ Algae secretes oily substances that may result in bad taste and odour.
- **Objection :** The taste and odour causing compounds may be carcinogenic.

➤ **Measurement :**

Measurement of taste and odour causing organics can be done using gas or liquid chromatography. However this method is costly and not done in routine. Intensity of taste and odour is measured by **Threshold Odour Number(TON)**. It represents the dilution ratio at which odour is hardly detectable. TON allowed is between 1 – 3. TON testing is done in cold water because increase in temperature may change the taste and odour. The formula for $TON = \frac{A+B}{A}$ where A is the volume of odourous water in mL and B is the volume of odour free water required to produce a mixture in which odour is hardly detectable. Odours can be removed by mechanical aeration, oxidation by chemicals like chlorine or its compounds or ozone or permanganate and adsorption of odour by agents such as activated carbon, flock or clays.

4. Colour

- **Source :** Colour is caused by suspended and dissolved matter in water.

After suspended matter causing colour is removed by centrifugation, the colour obtained is called true colour. Humic acid gives yellowish brown colour, Iron oxide gives reddish colour, manganese oxide gives brown or blackish water. Water containing oxidised iron and manganese impart characteristic reddish or black colour. Heavy growth of algae may also impart colour to the water.

- **Objection :**

Coloured water is not suitable for dying purpose. Organic compounds causing colour may exert chlorine demand and hence reduces the effectiveness of disinfection by chlorine. Phenolic compound with chlorine produces taste and odour. Some colour causing organic compounds with chlorine becomes carcinogenic.

- **Measurement:**

Measurement of colour is done by colour matching technique (tintometer). Result is expressed in TCU or Hazen unit (True colour unit) where 1 TCU is equal to colour produced by 1 mg per litre of platinum in the form of chloroplatinate ion (It is only for yellowish brown colour). For colour other than yellowish brown i.e. from industrial effluent, spectro photometric technique is used. The colour testing is done within 72 hours of collection as effluent biological or physical properties may change.

- **Permissible limit :** Acceptable limit is 5 TCU and cause for rejection is 25 TCU

5. Temperature :

Temperature affects the chemical and biological reactions. An increase in 10°C, doubles the biological activity. Hence for water supply, the temperature should be between 10-25°C and greater than 25°C is objectionable.